

[Login](#)

Summary of	DAIKIN ALTHERMA 3 H MT F+W 10KW (180L)	Reg. No.	011-1W0507
Certificate Holder			
Name	DAIKIN Europe N.V.		
Address	Zandvoordestraat 300	Zip	B-8400
City	Oostende	Country	Belgium
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	DAIKIN ALTHERMA 3 H MT F+W 10KW (180L)		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R32		
Mass of Refrigerant	3.25 kg		
Certification Date	24.11.2021		
Testing basis	HP KEYMARK certification scheme rules rev. 9		

Model: EPRA10EV3 / ETBH12E(6V/9W)

Configure model	
Model name	EPRA10EV3 / ETBH12E(6V/9W)
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	6.17 kW	7.72 kW
El input	1.25 kW	2.63 kW
COP	4.92	2.94

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2**+7°C/+12°C**

El input

2.66 kW

Cooling capacity

7.97

EER

3.00

EN 14825

This information was generated by the HP KEYMARK database on 23 Jun 2022

	+7°C/+12°C
P _{designc}	7.5 kW
SEER	5.34
P _{dc Tj = 35°C}	7.97 kW
EER T _{j = 35°C}	3.00
P _{dc Tj = 30°C}	5.76 kW
EER T _{j = 30°C}	4.28
C _{dc}	0.98
P _{dc Tj = 25°C}	3.63 kW
EER T _{j = 25°C}	6.31
C _{dc}	0.95
P _{dc Tj = 20°C}	2.63 kW
EER T _{j = 20°C}	8.37
C _{dc}	0.91
P _{off}	99 W
PTO	99 W
PSB	99 W
PCK	99 W
Annual energy consumption Q _{ce}	843 kWh

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	44.0 dB(A)	44.0 dB(A)
Sound power level outdoor	53.0 dB(A)	53.0 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	186 %	134 %
Prated	8.3 kW	8.5 kW
SCOP	4.71	3.43
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.5 kW	7.6 kW
COP Tj = -7°C	3.10	2.21
Cdh Tj = -7 °C	1.0	1.0
Pdh Tj = +2°C	4.4 kW	4.6 kW
COP Tj = +2°C	4.76	3.37
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	4.3 kW	3.0 kW
COP Tj = +7°C	6.14	4.48
Cdh Tj = +7 °C	1.0	1.0

This information was generated by the HP KEYMARK database on 23 Jun 2022

Pdh Tj = 12°C	6.6 kW	3.7 kW
COP Tj = 12°C	7.84	5.98
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	8.1 kW	8.3 kW
COP Tj = Tbiv	2.77	1.97
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.1 kW	8.3 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.77	1.97
WTOL	35 °C	55 °C
Poff	21 W	21 W
PTO	24 W	24 W
PSB	21 W	21 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.0 kW	0.0 kW
Annual energy consumption Qhe	3637 kWh	5120 kWh

Model: EPRA10EV3 / ETBX12E(6V/9W)

Configure model	
Model name	EPRA10EV3 / ETBX12E(6V/9W)
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	6.17 kW	7.72 kW
El input	1.25 kW	2.63 kW
COP	4.92	2.94

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2**+7°C/+12°C**

El input

2.66 kW

Cooling capacity

7.97

EER

3.00

EN 14825

This information was generated by the HP KEYMARK database on 23 Jun 2022

	+7°C/+12°C
P _{designc}	7.50 kW
SEER	5.34
P _{dc Tj = 35°C}	7.97 kW
EER T _{j = 35°C}	3.00
P _{dc Tj = 30°C}	5.76 kW
EER T _{j = 30°C}	4.28
C _{dc}	0.980
P _{dc Tj = 25°C}	3.63 kW
EER T _{j = 25°C}	6.31
C _{dc}	0.950
P _{dc Tj = 20°C}	2.63 kW
EER T _{j = 20°C}	8.37
C _{dc}	0.910
P _{off}	25 W
PTO	3 W
PSB	25 W
PCK	0 W
Annual energy consumption Q _{ce}	843 kWh

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	44.0 dB(A)	44.0 dB(A)
Sound power level outdoor	53.0 dB(A)	53.0 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	190 %	136 %
Prated	8.3 kW	8.5 kW
SCOP	4.82	3.48
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.5 kW	7.6 kW
COP Tj = -7°C	3.10	2.21
Cdh Tj = -7 °C	1.0	1.0
Pdh Tj = +2°C	4.4 kW	4.6 kW
COP Tj = +2°C	4.76	3.37
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	4.3 kW	3.0 kW
COP Tj = +7°C	6.14	4.48
Cdh Tj = +7 °C	1.0	1.0

This information was generated by the HP KEYMARK database on 23 Jun 2022

Pdh Tj = 12°C	6.6 kW	3.7 kW
COP Tj = 12°C	7.84	5.98
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	8.1 kW	8.3 kW
COP Tj = Tbiv	2.77	1.97
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.1 kW	8.3 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.77	1.97
WTOL	35 °C	55 °C
Poff	21 W	21 W
PTO	24 W	24 W
PSB	21 W	21 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.0 kW	0.0 kW
Annual energy consumption Qhe	3560 kWh	5043 kWh

Model: EPRA10EV3 / ETVH12S18E(6V/9W)

Configure model	
Model name	EPRA10EV3 / ETVH12S18E(6V/9W)
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	6.17 kW	7.72 kW
El input	1.25 kW	2.63 kW
COP	4.92	2.94

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2

	+7°C/+12°C
El input	2.66 kW
Cooling capacity	7.97
EER	3.00

EN 14825

This information was generated by the HP KEYMARK database on 23 Jun 2022

	+7°C/+12°C
Pdesignc	7.5 kW
SEER	5.34
Pdc Tj = 35°C	7.97 kW
EER Tj = 35°C	3.00
Pdc Tj = 30°C	5.76 kW
EER Tj = 30°C	4.28
Cdc	0.98
Pdc Tj = 25°C	3.63 kW
EER Tj = 25°C	6.31
Cdc	0.95
Pdc Tj = 20°C	2.63 kW
EER Tj = 20°C	8.37
Cdc	0.91
Poff	99 W
PTO	99 W
PSB	99 W
PCK	99 W
Annual energy consumption Qce	843 kWh

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	44.0 dB(A)	44.0 dB(A)
Sound power level outdoor	53.0 dB(A)	53.0 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	186 %	134 %
Prated	8.3 kW	8.5 kW
SCOP	4.71	3.43
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.5 kW	7.6 kW
COP Tj = -7°C	3.10	2.21
Cdh Tj = -7 °C	1.0	1.0
Pdh Tj = +2°C	4.4 kW	4.6 kW
COP Tj = +2°C	4.76	3.37
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	4.3 kW	3.0 kW
COP Tj = +7°C	6.14	4.48
Cdh Tj = +7 °C	1.0	1.0

This information was generated by the HP KEYMARK database on 23 Jun 2022

Pdh Tj = 12°C	6.6 kW	3.7 kW
COP Tj = 12°C	7.84	5.98
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	8.1 kW	8.3 kW
COP Tj = Tbiv	2.77	1.97
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.1 kW	8.3 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.77	1.97
WTOL	35 °C	55 °C
Poff	21 W	21 W
PTO	24 W	24 W
PSB	21 W	21 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.0 kW	0.0 kW
Annual energy consumption Qhe	3637 kWh	5120 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	117 %
COP	2.72
Heating up time	1:57 h:min
Standby power input	51.7 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	240 l

Model: EPRA10EV3 / ETVH12SU18E6V

Configure model	
Model name	EPRA10EV3 / ETVH12SU18E6V
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	6.17 kW	7.72 kW
El input	1.25 kW	2.63 kW
COP	4.92	2.94

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2

	+7°C/+12°C
El input	2.66 kW
Cooling capacity	7.97
EER	3.00

EN 14825

This information was generated by the HP KEYMARK database on 23 Jun 2022

	+7°C/+12°C
P _{designc}	7.5 kW
SEER	5.34
P _{dc Tj = 35°C}	7.97 kW
EER T _{j = 35°C}	3.00
P _{dc Tj = 30°C}	5.76 kW
EER T _{j = 30°C}	4.28
C _{dc}	0.98
P _{dc Tj = 25°C}	3.63 kW
EER T _{j = 25°C}	6.31
C _{dc}	0.95
P _{dc Tj = 20°C}	2.63 kW
EER T _{j = 20°C}	8.37
C _{dc}	0.91
P _{off}	99 W
PTO	99 W
PSB	99 W
PCK	99 W
Annual energy consumption Q _{ce}	843 kWh

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	44.0 dB(A)	44.0 dB(A)
Sound power level outdoor	53.0 dB(A)	53.0 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	186 %	134 %
Prated	8.3 kW	8.5 kW
SCOP	4.71	3.43
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.5 kW	7.6 kW
COP Tj = -7°C	3.10	2.21
Cdh Tj = -7 °C	1.0	1.0
Pdh Tj = +2°C	4.4 kW	4.6 kW
COP Tj = +2°C	4.76	3.37
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	4.3 kW	3.0 kW
COP Tj = +7°C	6.14	4.48
Cdh Tj = +7 °C	1.0	1.0

This information was generated by the HP KEYMARK database on 23 Jun 2022

Pdh Tj = 12°C	6.6 kW	3.7 kW
COP Tj = 12°C	7.84	5.98
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	8.1 kW	8.3 kW
COP Tj = Tbiv	2.77	1.97
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.1 kW	8.3 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.77	1.97
WTOL	35 °C	55 °C
Poff	21 W	21 W
PTO	24 W	24 W
PSB	21 W	21 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.0 kW	0.0 kW
Annual energy consumption Qhe	3637 kWh	5120 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	117 %
COP	2.72
Heating up time	1:57 h:min
Standby power input	51.7 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	240 l

Model: EPRA10EV3 / ETVX12S18E(6V/9W)

Configure model	
Model name	EPRA10EV3 / ETVX12S18E(6V/9W)
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	6.17 kW	7.72 kW
El input	1.25 kW	2.63 kW
COP	4.92	2.94

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2

	+7°C/+12°C
El input	2.66 kW
Cooling capacity	7.97
EER	3.00

EN 14825

This information was generated by the HP KEYMARK database on 23 Jun 2022

	+7°C/+12°C
P _{designc}	7.50 kW
SEER	5.34
P _{dc Tj = 35°C}	7.97 kW
EER Tj = 35°C	3.00
P _{dc Tj = 30°C}	5.76 kW
EER Tj = 30°C	4.28
C _{dc}	0.980
P _{dc Tj = 25°C}	3.63 kW
EER Tj = 25°C	6.31
C _{dc}	0.950
P _{dc Tj = 20°C}	2.63 kW
EER Tj = 20°C	8.37
C _{dc}	0.910
P _{off}	25 W
PTO	3 W
PSB	25 W
PCK	0 W
Annual energy consumption Q _{ce}	843 kWh

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	44.0 dB(A)	44.0 dB(A)
Sound power level outdoor	53.0 dB(A)	53.0 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	190 %	136 %
Prated	8.3 kW	8.5 kW
SCOP	4.82	3.48
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.5 kW	7.6 kW
COP Tj = -7°C	3.10	2.21
Cdh Tj = -7 °C	1.0	1.0
Pdh Tj = +2°C	4.4 kW	4.6 kW
COP Tj = +2°C	4.76	3.37
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	4.3 kW	3.0 kW
COP Tj = +7°C	6.14	4.48
Cdh Tj = +7 °C	1.0	1.0

This information was generated by the HP KEYMARK database on 23 Jun 2022

Pdh Tj = 12°C	6.6 kW	3.7 kW
COP Tj = 12°C	7.84	5.98
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	8.1 kW	8.3 kW
COP Tj = Tbiv	2.77	1.97
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.1 kW	8.3 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.77	1.97
WTOL	35 °C	55 °C
Poff	21 W	21 W
PTO	24 W	24 W
PSB	21 W	21 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.0 kW	0.0 kW
Annual energy consumption Qhe	3560 kWh	5043 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	117 %
COP	2.72
Heating up time	1:57 h:min
Standby power input	51.7 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	240 l

Model: EPRA10EV3 / ETVZ12S18E(6V/9W)

Configure model	
Model name	EPRA10EV3 / ETVZ12S18E(6V/9W)
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	6.17 kW	7.72 kW
El input	1.25 kW	2.63 kW
COP	4.92	2.94

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2

	+7°C/+12°C
El input	2.66 kW
Cooling capacity	7.97
EER	3.00

EN 14825

This information was generated by the HP KEYMARK database on 23 Jun 2022

	+7°C/+12°C
Pdesignc	7.5 kW
SEER	5.34
Pdc Tj = 35°C	7.97 kW
EER Tj = 35°C	3.00
Pdc Tj = 30°C	5.76 kW
EER Tj = 30°C	4.28
Cdc	0.98
Pdc Tj = 25°C	3.63 kW
EER Tj = 25°C	6.31
Cdc	0.95
Pdc Tj = 20°C	2.63 kW
EER Tj = 20°C	8.37
Cdc	0.91
Poff	99 W
PTO	99 W
PSB	99 W
PCK	99 W
Annual energy consumption Qce	843 kWh

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	44.0 dB(A)	44.0 dB(A)
Sound power level outdoor	53.0 dB(A)	53.0 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	186 %	134 %
Prated	8.3 kW	8.5 kW
SCOP	4.71	3.43
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.5 kW	7.6 kW
COP Tj = -7°C	3.10	2.21
Cdh Tj = -7 °C	1.0	1.0
Pdh Tj = +2°C	4.4 kW	4.6 kW
COP Tj = +2°C	4.76	3.37
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	4.3 kW	3.0 kW
COP Tj = +7°C	6.14	4.48
Cdh Tj = +7 °C	1.0	1.0

This information was generated by the HP KEYMARK database on 23 Jun 2022

Pdh Tj = 12°C	6.6 kW	3.7 kW
COP Tj = 12°C	7.84	5.98
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	8.1 kW	8.3 kW
COP Tj = Tbiv	2.77	1.97
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.1 kW	8.3 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.77	1.97
WTOL	35 °C	55 °C
Poff	21 W	21 W
PTO	24 W	24 W
PSB	21 W	21 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.0 kW	0.0 kW
Annual energy consumption Qhe	3637 kWh	5120 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	117 %
COP	2.72
Heating up time	1:57 h:min
Standby power input	51.7 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	240 l

Model: EPRA10EW1 / ETBH12E(6V/9W)

Configure model	
Model name	EPRA10EW1 / ETBH12E(6V/9W)
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	6.17 kW	7.72 kW
El input	1.21 kW	2.53 kW
COP	5.10	3.05

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2

	+7°C/+12°C
El input	2.57 kW
Cooling capacity	7.97
EER	3.10

EN 14825

This information was generated by the HP KEYMARK database on 23 Jun 2022

	+7°C/+12°C
P _{designc}	7.5 kW
SEER	5.41
P _{dc Tj = 35°C}	7.97 kW
EER T _j = 35°C	3.10
P _{dc Tj = 30°C}	5.76 kW
EER T _j = 30°C	4.43
C _{dc}	0.98
P _{dc Tj = 25°C}	3.63 kW
EER T _j = 25°C	6.47
C _{dc}	0.95
P _{dc Tj = 20°C}	2.63 kW
EER T _j = 20°C	8.35
C _{dc}	0.91
P _{off}	99 W
PTO	99 W
PSB	99 W
PCK	99 W
Annual energy consumption Q _{ce}	831 kWh

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	44.0 dB(A)	44.0 dB(A)
Sound power level outdoor	53.0 dB(A)	53.0 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	191 %	138 %
Prated	8.3 kW	8.5 kW
SCOP	4.84	3.53
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.5 kW	7.6 kW
COP Tj = -7°C	3.20	2.30
Cdh Tj = -7 °C	1.0	1.0
Pdh Tj = +2°C	4.4 kW	4.6 kW
COP Tj = +2°C	4.93	3.50
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	4.3 kW	3.0 kW
COP Tj = +7°C	6.37	4.61
Cdh Tj = +7 °C	1.0	1.0

This information was generated by the HP KEYMARK database on 23 Jun 2022

Pdh Tj = 12°C	6.6 kW	3.7 kW
COP Tj = 12°C	8.13	6.16
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	8.1 kW	8.3 kW
COP Tj = Tbiv	2.86	2.05
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.1 kW	8.3 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.86	2.05
WTOL	35 °C	55 °C
Poff	27 W	27 W
PTO	24 W	24 W
PSB	27 W	27 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.0 kW	0.0 kW
Annual energy consumption Qhe	3539 kWh	4970 kWh

Model: EPRA10EW1 / ETBX12E(6V/9W)

Configure model	
Model name	EPRA10EW1 / ETBX12E(6V/9W)
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	6.17 kW	7.72 kW
El input	1.21 kW	2.53 kW
COP	5.10	3.05

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2**+7°C/+12°C**

El input

2.57 kW

Cooling capacity

7.97

EER

3.10

EN 14825

This information was generated by the HP KEYMARK database on 23 Jun 2022

	+7°C/+12°C
Pdesignc	7.50 kW
SEER	5.41
Pdc Tj = 35°C	7.97 kW
EER Tj = 35°C	3.10
Pdc Tj = 30°C	5.76 kW
EER Tj = 30°C	4.43
Cdc	0.980
Pdc Tj = 25°C	3.63 kW
EER Tj = 25°C	6.47
Cdc	0.950
Pdc Tj = 20°C	2.63 kW
EER Tj = 20°C	8.35
Cdc	0.910
Poff	31 W
PTO	0 W
PSB	31 W
PCK	0 W
Annual energy consumption Qce	831 kWh

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	44.0 dB(A)	44.0 dB(A)
Sound power level outdoor	53.0 dB(A)	53.0 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	196 %	141 %
Prated	8.3 kW	8.5 kW
SCOP	4.98	3.60
Tbiv	-7 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.5 kW	7.6 kW
COP Tj = -7°C	3.20	2.30
Cdh Tj = -7 °C	1.0	1.0
Pdh Tj = +2°C	4.4 kW	4.6 kW
COP Tj = +2°C	4.93	3.50
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	4.3 kW	3.0 kW
COP Tj = +7°C	6.37	4.61
Cdh Tj = +7 °C	1.0	1.0

This information was generated by the HP KEYMARK database on 23 Jun 2022

Pdh Tj = 12°C	6.6 kW	3.7 kW
COP Tj = 12°C	8.13	6.16
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	8.1 kW	8.3 kW
COP Tj = Tbiv	2.86	2.05
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.1 kW	8.3 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.86	2.05
WTOL	35 °C	55 °C
Poff	27 W	27 W
PTO	24 W	24 W
PSB	27 W	27 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.0 kW	0.0 kW
Annual energy consumption Qhe	3440 kWh	4871 kWh

Model: EPRA10EW1 / ETVH12S18E(6V/9W)

Configure model	
Model name	EPRA10EW1 / ETVH12S18E(6V/9W)
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	6.17 kW	7.72 kW
El input	1.21 kW	2.53 kW
COP	5.10	3.05

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2**+7°C/+12°C**

El input

2.57 kW

Cooling capacity

7.97

EER

3.10

EN 14825

This information was generated by the HP KEYMARK database on 23 Jun 2022

	+7°C/+12°C
Pdesignc	7.5 kW
SEER	5.41
Pdc Tj = 35°C	7.97 kW
EER Tj = 35°C	3.10
Pdc Tj = 30°C	5.76 kW
EER Tj = 30°C	4.43
Cdc	0.98
Pdc Tj = 25°C	3.63 kW
EER Tj = 25°C	6.47
Cdc	0.95
Pdc Tj = 20°C	2.63 kW
EER Tj = 20°C	8.35
Cdc	0.91
Poff	99 W
PTO	99 W
PSB	99 W
PCK	99 W
Annual energy consumption Qce	831 kWh

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	44.0 dB(A)	44.0 dB(A)
Sound power level outdoor	53.0 dB(A)	53.0 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	191 %	138 %
Prated	8.3 kW	8.5 kW
SCOP	4.84	3.53
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.5 kW	7.6 kW
COP Tj = -7°C	3.20	2.30
Cdh Tj = -7 °C	1.0	1.0
Pdh Tj = +2°C	4.4 kW	4.6 kW
COP Tj = +2°C	4.93	3.50
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	4.3 kW	3.0 kW
COP Tj = +7°C	6.37	4.61
Cdh Tj = +7 °C	1.0	1.0

This information was generated by the HP KEYMARK database on 23 Jun 2022

Pdh Tj = 12°C	6.6 kW	3.7 kW
COP Tj = 12°C	8.13	6.16
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	8.1 kW	8.3 kW
COP Tj = Tbiv	2.86	2.05
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.1 kW	8.3 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.86	2.05
WTOL	35 °C	55 °C
Poff	27 W	27 W
PTO	24 W	24 W
PSB	27 W	27 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.0 kW	0.0 kW
Annual energy consumption Qhe	3539 kWh	4970 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	120 %
COP	2.80
Heating up time	1:57 h:min
Standby power input	50.7 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	240 l

Model: EPRA10EW1 / ETVH12SU18E6V

Configure model	
Model name	EPRA10EW1 / ETVH12SU18E6V
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	6.17 kW	7.72 kW
El input	1.21 kW	2.53 kW
COP	5.10	3.05

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2

	+7°C/+12°C
El input	2.57 kW
Cooling capacity	7.97
EER	3.10

EN 14825

This information was generated by the HP KEYMARK database on 23 Jun 2022

	+7°C/+12°C
Pdesignc	7.5 kW
SEER	5.41
Pdc Tj = 35°C	7.97 kW
EER Tj = 35°C	3.10
Pdc Tj = 30°C	5.76 kW
EER Tj = 30°C	4.43
Cdc	0.98
Pdc Tj = 25°C	3.63 kW
EER Tj = 25°C	6.47
Cdc	0.95
Pdc Tj = 20°C	2.63 kW
EER Tj = 20°C	8.35
Cdc	0.91
Poff	99 W
PTO	99 W
PSB	99 W
PCK	99 W
Annual energy consumption Qce	831 kWh

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	44.0 dB(A)	44.0 dB(A)
Sound power level outdoor	53.0 dB(A)	53.0 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	191 %	138 %
Prated	8.3 kW	8.5 kW
SCOP	4.84	3.53
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.5 kW	7.6 kW
COP Tj = -7°C	3.20	2.30
Cdh Tj = -7 °C	1.0	1.0
Pdh Tj = +2°C	4.4 kW	4.6 kW
COP Tj = +2°C	4.93	3.50
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	4.3 kW	3.0 kW
COP Tj = +7°C	6.37	4.61
Cdh Tj = +7 °C	1.0	1.0

This information was generated by the HP KEYMARK database on 23 Jun 2022

Pdh Tj = 12°C	6.6 kW	3.7 kW
COP Tj = 12°C	8.13	6.16
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	8.1 kW	8.3 kW
COP Tj = Tbiv	2.86	2.05
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.1 kW	8.3 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.86	2.05
WTOL	35 °C	55 °C
Poff	27 W	27 W
PTO	24 W	24 W
PSB	27 W	27 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.0 kW	0.0 kW
Annual energy consumption Qhe	3539 kWh	4970 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	120 %
COP	2.80
Heating up time	1:57 h:min
Standby power input	50.7 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	240 l

Model: EPRA10EW1 / ETVX12S18E(6V/9W)

Configure model	
Model name	EPRA10EW1 / ETVX12S18E(6V/9W)
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	6.17 kW	7.72 kW
El input	1.21 kW	2.53 kW
COP	5.10	3.05

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2**+7°C/+12°C**

El input

2.57 kW

Cooling capacity

7.97

EER

3.10

EN 14825

This information was generated by the HP KEYMARK database on 23 Jun 2022

	+7°C/+12°C
P _{designc}	7.50 kW
SEER	5.41
P _{dc Tj = 35°C}	7.97 kW
EER T _j = 35°C	3.10
P _{dc Tj = 30°C}	5.76 kW
EER T _j = 30°C	4.43
C _{dc}	0.980
P _{dc Tj = 25°C}	3.63 kW
EER T _j = 25°C	6.47
C _{dc}	0.950
P _{dc Tj = 20°C}	2.63 kW
EER T _j = 20°C	8.35
C _{dc}	0.910
P _{off}	31 W
PTO	0 W
PSB	31 W
PCK	0 W
Annual energy consumption Q _{ce}	831 kWh

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	44.0 dB(A)	44.0 dB(A)
Sound power level outdoor	53.0 dB(A)	53.0 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	196 %	141 %
Prated	8.3 kW	8.5 kW
SCOP	4.98	3.60
Tbiv	-7 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.5 kW	7.6 kW
COP Tj = -7°C	3.20	2.30
Cdh Tj = -7 °C	1.0	1.0
Pdh Tj = +2°C	4.4 kW	4.6 kW
COP Tj = +2°C	4.93	3.50
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	4.3 kW	3.0 kW
COP Tj = +7°C	6.37	4.61
Cdh Tj = +7 °C	1.0	1.0

This information was generated by the HP KEYMARK database on 23 Jun 2022

Pdh Tj = 12°C	6.6 kW	3.7 kW
COP Tj = 12°C	8.13	6.16
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	8.1 kW	8.3 kW
COP Tj = Tbiv	2.86	2.05
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.1 kW	8.3 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.86	2.05
WTOL	35 °C	55 °C
Poff	27 W	27 W
PTO	24 W	24 W
PSB	27 W	27 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.0 kW	0.0 kW
Annual energy consumption Qhe	3440 kWh	4871 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	120 %
COP	2.80
Heating up time	1:57 h:min
Standby power input	50.7 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	240 l

Model: EPRA10EW1 / ETVZ12S18E(6V/9W)

Configure model	
Model name	EPRA10EW1 / ETVZ12S18E(6V/9W)
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	6.17 kW	7.72 kW
El input	1.21 kW	2.53 kW
COP	5.10	3.05

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2**+7°C/+12°C**

El input

2.57 kW

Cooling capacity

7.97

EER

3.10

EN 14825

This information was generated by the HP KEYMARK database on 23 Jun 2022

	+7°C/+12°C
P _{designc}	7.5 kW
SEER	5.41
P _{dc Tj = 35°C}	7.97 kW
EER T _{j = 35°C}	3.10
P _{dc Tj = 30°C}	5.76 kW
EER T _{j = 30°C}	4.43
C _{dc}	0.98
P _{dc Tj = 25°C}	3.63 kW
EER T _{j = 25°C}	6.47
C _{dc}	0.95
P _{dc Tj = 20°C}	2.63 kW
EER T _{j = 20°C}	8.35
C _{dc}	0.91
P _{off}	99 W
PTO	99 W
PSB	99 W
PCK	99 W
Annual energy consumption Q _{ce}	831 kWh

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	44.0 dB(A)	44.0 dB(A)
Sound power level outdoor	53.0 dB(A)	53.0 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	191 %	138 %
Prated	8.3 kW	8.5 kW
SCOP	4.84	3.53
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.5 kW	7.6 kW
COP Tj = -7°C	3.20	2.30
Cdh Tj = -7 °C	1.0	1.0
Pdh Tj = +2°C	4.4 kW	4.6 kW
COP Tj = +2°C	4.93	3.50
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	4.3 kW	3.0 kW
COP Tj = +7°C	6.37	4.61
Cdh Tj = +7 °C	1.0	1.0

This information was generated by the HP KEYMARK database on 23 Jun 2022

Pdh Tj = 12°C	6.6 kW	3.7 kW
COP Tj = 12°C	8.13	6.16
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	8.1 kW	8.3 kW
COP Tj = Tbiv	2.86	2.05
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.1 kW	8.3 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.86	2.05
WTOL	35 °C	55 °C
Poff	27 W	27 W
PTO	24 W	24 W
PSB	27 W	27 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.0 kW	0.0 kW
Annual energy consumption Qhe	3539 kWh	4970 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	120 %
COP	2.80
Heating up time	1:57 h:min
Standby power input	50.7 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	240 l

Model: EPRA10EV3 / ETBH12E(6V/9W) + cooling kit

Configure model	
Model name	EPRA10EV3 / ETBH12E(6V/9W) + cooling kit
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	6.17 kW	7.72 kW
El input	1.25 kW	2.63 kW
COP	4.92	2.94

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2

	+7°C/+12°C
El input	2.66 kW
Cooling capacity	7.97
EER	3.00

EN 14825

This information was generated by the HP KEYMARK database on 23 Jun 2022

	+7°C/+12°C
P _{designc}	7.50 kW
SEER	5.34
P _{dc Tj = 35°C}	7.97 kW
EER T _j = 35°C	3.00
P _{dc Tj = 30°C}	5.76 kW
EER T _j = 30°C	4.28
C _{dc}	0.980
P _{dc Tj = 25°C}	3.63 kW
EER T _j = 25°C	6.31
C _{dc}	0.950
P _{dc Tj = 20°C}	2.63 kW
EER T _j = 20°C	8.37
C _{dc}	0.910
P _{off}	25 W
PTO	3 W
PSB	25 W
PCK	0 W
Annual energy consumption Q _{ce}	843 kWh

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	44.0 dB(A)	44.0 dB(A)
Sound power level outdoor	53.0 dB(A)	53.0 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	190 %	136 %
Prated	8.3 kW	8.5 kW
SCOP	4.82	3.48
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.5 kW	7.6 kW
COP Tj = -7°C	3.10	2.21
Cdh Tj = -7 °C	1.0	1.0
Pdh Tj = +2°C	4.4 kW	4.6 kW
COP Tj = +2°C	4.76	3.37
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	4.3 kW	3.0 kW
COP Tj = +7°C	6.14	4.48
Cdh Tj = +7 °C	1.0	1.0

This information was generated by the HP KEYMARK database on 23 Jun 2022

Pdh Tj = 12°C	6.6 kW	3.7 kW
COP Tj = 12°C	7.84	5.98
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	8.1 kW	8.3 kW
COP Tj = Tbiv	2.77	1.97
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.1 kW	8.3 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.77	1.97
WTOL	35 °C	55 °C
Poff	21 W	21 W
PTO	24 W	24 W
PSB	21 W	21 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.0 kW	0.0 kW
Annual energy consumption Qhe	3560 kWh	5043 kWh

Model: EPRA10EV3 / ETVH12S18E(6V/9W) + cooling kit

Configure model	
Model name	EPRA10EV3 / ETVH12S18E(6V/9W) + cooling kit
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	6.17 kW	7.72 kW
El input	1.25 kW	2.63 kW
COP	4.92	2.94

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2

	+7°C/+12°C
El input	2.66 kW
Cooling capacity	7.97
EER	3.00

EN 14825

This information was generated by the HP KEYMARK database on 23 Jun 2022

	+7°C/+12°C
P _{designc}	7.50 kW
SEER	5.34
P _{dc Tj = 35°C}	7.97 kW
EER T _{j = 35°C}	3.00
P _{dc Tj = 30°C}	5.76 kW
EER T _{j = 30°C}	4.28
C _{dc}	0.980
P _{dc Tj = 25°C}	3.63 kW
EER T _{j = 25°C}	6.31
C _{dc}	0.950
P _{dc Tj = 20°C}	2.63 kW
EER T _{j = 20°C}	8.37
C _{dc}	0.910
P _{off}	25 W
PTO	3 W
PSB	25 W
PCK	0 W
Annual energy consumption Q _{ce}	843 kWh

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	44.0 dB(A)	44.0 dB(A)
Sound power level outdoor	53.0 dB(A)	53.0 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	190 %	136 %
Prated	8.3 kW	8.5 kW
SCOP	4.82	3.48
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.5 kW	7.6 kW
COP Tj = -7°C	3.10	2.21
Cdh Tj = -7 °C	1.0	1.0
Pdh Tj = +2°C	4.4 kW	4.6 kW
COP Tj = +2°C	4.76	3.37
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	4.3 kW	3.0 kW
COP Tj = +7°C	6.14	4.48
Cdh Tj = +7 °C	1.0	1.0

This information was generated by the HP KEYMARK database on 23 Jun 2022

Pdh Tj = 12°C	6.6 kW	3.7 kW
COP Tj = 12°C	7.84	5.98
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	8.1 kW	8.3 kW
COP Tj = Tbiv	2.77	1.97
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.1 kW	8.3 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.77	1.97
WTOL	35 °C	55 °C
Poff	21 W	21 W
PTO	24 W	24 W
PSB	21 W	21 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.0 kW	0.0 kW
Annual energy consumption Qhe	3560 kWh	5043 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	117 %
COP	2.72
Heating up time	1:57 h:min
Standby power input	51.7 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	240 l

Model: EPRA10EW1 / ETBH12E(6V/9W) + cooling kit

Configure model	
Model name	EPRA10EW1 / ETBH12E(6V/9W) + cooling kit
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	6.17 kW	7.72 kW
El input	1.21 kW	2.53 kW
COP	5.10	3.05

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2**+7°C/+12°C**

El input

2.57 kW

Cooling capacity

7.97

EER

3.10

EN 14825

This information was generated by the HP KEYMARK database on 23 Jun 2022

	+7°C/+12°C
P _{designc}	7.50 kW
SEER	5.41
P _{dc Tj = 35°C}	7.97 kW
EER Tj = 35°C	3.10
P _{dc Tj = 30°C}	5.76 kW
EER Tj = 30°C	4.43
C _{dc}	0.980
P _{dc Tj = 25°C}	3.63 kW
EER Tj = 25°C	6.47
C _{dc}	0.950
P _{dc Tj = 20°C}	2.63 kW
EER Tj = 20°C	8.35
C _{dc}	0.910
P _{off}	31 W
PTO	0 W
PSB	31 W
PCK	0 W
Annual energy consumption Q _{ce}	831 kWh

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	44.0 dB(A)	44.0 dB(A)
Sound power level outdoor	53.0 dB(A)	53.0 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	196 %	141 %
Prated	8.3 kW	8.5 kW
SCOP	4.98	3.60
Tbiv	-7 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.5 kW	7.6 kW
COP Tj = -7°C	3.20	2.30
Cdh Tj = -7 °C	1.0	1.0
Pdh Tj = +2°C	4.4 kW	4.6 kW
COP Tj = +2°C	4.93	3.50
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	4.3 kW	3.0 kW
COP Tj = +7°C	6.37	4.61
Cdh Tj = +7 °C	1.0	1.0

This information was generated by the HP KEYMARK database on 23 Jun 2022

Pdh Tj = 12°C	6.6 kW	3.7 kW
COP Tj = 12°C	8.13	6.16
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	8.1 kW	8.3 kW
COP Tj = Tbiv	2.86	2.05
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.1 kW	8.3 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.86	2.05
WTOL	35 °C	55 °C
Poff	27 W	27 W
PTO	24 W	24 W
PSB	27 W	27 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.0 kW	0.0 kW
Annual energy consumption Qhe	3440 kWh	4871 kWh

Model: EPRA10EW1 / ETVH12S18E(6V/9W) + cooling kit

Configure model	
Model name	EPRA10EW1 / ETVH12S18E(6V/9W) + cooling kit
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	6.17 kW	7.72 kW
El input	1.21 kW	2.53 kW
COP	5.10	3.05

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2

	+7°C/+12°C
El input	2.57 kW
Cooling capacity	7.97
EER	3.10

EN 14825

This information was generated by the HP KEYMARK database on 23 Jun 2022

	+7°C/+12°C
P _{designc}	7.50 kW
SEER	5.41
P _{dc Tj = 35°C}	7.97 kW
EER T _j = 35°C	3.10
P _{dc Tj = 30°C}	5.76 kW
EER T _j = 30°C	4.43
C _{dc}	0.980
P _{dc Tj = 25°C}	3.63 kW
EER T _j = 25°C	6.47
C _{dc}	0.950
P _{dc Tj = 20°C}	2.63 kW
EER T _j = 20°C	8.35
C _{dc}	0.910
P _{off}	31 W
PTO	0 W
PSB	31 W
PCK	0 W
Annual energy consumption Q _{ce}	831 kWh

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	44.0 dB(A)	44.0 dB(A)
Sound power level outdoor	53.0 dB(A)	53.0 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	196 %	141 %
Prated	8.3 kW	8.5 kW
SCOP	4.98	3.60
Tbiv	-7 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.5 kW	7.6 kW
COP Tj = -7°C	3.20	2.30
Cdh Tj = -7 °C	1.0	1.0
Pdh Tj = +2°C	4.4 kW	4.6 kW
COP Tj = +2°C	4.93	3.50
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	4.3 kW	3.0 kW
COP Tj = +7°C	6.37	4.61
Cdh Tj = +7 °C	1.0	1.0

This information was generated by the HP KEYMARK database on 23 Jun 2022

Pdh Tj = 12°C	6.6 kW	3.7 kW
COP Tj = 12°C	8.13	6.16
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	8.1 kW	8.3 kW
COP Tj = Tbiv	2.86	2.05
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.1 kW	8.3 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.86	2.05
WTOL	35 °C	55 °C
Poff	27 W	27 W
PTO	24 W	24 W
PSB	27 W	27 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.0 kW	0.0 kW
Annual energy consumption Qhe	3440 kWh	4871 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	120 %
COP	2.80
Heating up time	1:57 h:min
Standby power input	50.7 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	240 l

Model: EPRA10EV3 / ETVZ12S18E(6V/9W) + cooling kit

Configure model	
Model name	EPRA10EV3 / ETVZ12S18E(6V/9W) + cooling kit
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	6.17 kW	7.72 kW
El input	1.25 kW	2.63 kW
COP	4.92	2.94

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2

	+7°C/+12°C
El input	2.66 kW
Cooling capacity	7.97
EER	3.00

EN 14825

This information was generated by the HP KEYMARK database on 23 Jun 2022

	+7°C/+12°C
P _{designc}	7.50 kW
SEER	5.34
P _{dc Tj = 35°C}	7.97 kW
EER T _j = 35°C	3.00
P _{dc Tj = 30°C}	5.76 kW
EER T _j = 30°C	4.28
C _{dc}	0.980
P _{dc Tj = 25°C}	3.63 kW
EER T _j = 25°C	6.31
C _{dc}	0.950
P _{dc Tj = 20°C}	2.63 kW
EER T _j = 20°C	8.37
C _{dc}	0.910
P _{off}	25 W
PTO	3 W
PSB	25 W
PCK	0 W
Annual energy consumption Q _{ce}	843 kWh

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	44.0 dB(A)	44.0 dB(A)
Sound power level outdoor	53.0 dB(A)	53.0 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	190 %	136 %
Prated	8.3 kW	8.5 kW
SCOP	4.82	3.48
Tbiv	-10 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.5 kW	7.6 kW
COP Tj = -7°C	3.10	2.21
Cdh Tj = -7 °C	1.0	1.0
Pdh Tj = +2°C	4.4 kW	4.6 kW
COP Tj = +2°C	4.76	3.37
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	4.3 kW	3.0 kW
COP Tj = +7°C	6.14	4.48
Cdh Tj = +7 °C	1.0	1.0

This information was generated by the HP KEYMARK database on 23 Jun 2022

Pdh Tj = 12°C	6.6 kW	3.7 kW
COP Tj = 12°C	7.84	5.98
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	8.1 kW	8.3 kW
COP Tj = Tbiv	2.77	1.97
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.1 kW	8.3 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.77	1.97
WTOL	35 °C	55 °C
Poff	21 W	21 W
PTO	24 W	24 W
PSB	21 W	21 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.0 kW	0.0 kW
Annual energy consumption Qhe	3560 kWh	5043 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	117 %
COP	2.72
Heating up time	1:57 h:min
Standby power input	51.7 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	240 l

Model: EPRA10EW1 / ETVZ12S18E(6V/9W) + cooling kit

Configure model	
Model name	EPRA10EW1 / ETVZ12S18E(6V/9W) + cooling kit
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	6.17 kW	7.72 kW
El input	1.21 kW	2.53 kW
COP	5.10	3.05

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2

	+7°C/+12°C
El input	2.57 kW
Cooling capacity	7.97
EER	3.10

EN 14825

This information was generated by the HP KEYMARK database on 23 Jun 2022

	+7°C/+12°C
P _{designc}	7.50 kW
SEER	5.41
P _{dc Tj = 35°C}	7.97 kW
EER T _j = 35°C	3.10
P _{dc Tj = 30°C}	5.76 kW
EER T _j = 30°C	4.43
C _{dc}	0.980
P _{dc Tj = 25°C}	3.63 kW
EER T _j = 25°C	6.47
C _{dc}	0.950
P _{dc Tj = 20°C}	2.63 kW
EER T _j = 20°C	8.35
C _{dc}	0.910
P _{off}	31 W
PTO	0 W
PSB	31 W
PCK	0 W
Annual energy consumption Q _{ce}	831 kWh

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	44.0 dB(A)	44.0 dB(A)
Sound power level outdoor	53.0 dB(A)	53.0 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	196 %	141 %
Prated	8.3 kW	8.5 kW
SCOP	4.98	3.60
Tbiv	-7 °C	-10 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.5 kW	7.6 kW
COP Tj = -7°C	3.20	2.30
Cdh Tj = -7 °C	1.0	1.0
Pdh Tj = +2°C	4.4 kW	4.6 kW
COP Tj = +2°C	4.93	3.50
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	4.3 kW	3.0 kW
COP Tj = +7°C	6.37	4.61
Cdh Tj = +7 °C	1.0	1.0

This information was generated by the HP KEYMARK database on 23 Jun 2022

Pdh Tj = 12°C	6.6 kW	3.7 kW
COP Tj = 12°C	8.13	6.16
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	8.1 kW	8.3 kW
COP Tj = Tbiv	2.86	2.05
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	8.1 kW	8.3 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.86	2.05
WTOL	35 °C	55 °C
Poff	27 W	27 W
PTO	24 W	24 W
PSB	27 W	27 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.0 kW	0.0 kW
Annual energy consumption Qhe	3440 kWh	4871 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	120 %
COP	2.80
Heating up time	1:57 h:min
Standby power input	50.7 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	240 l