

[Login](#)

Summary of	DAIKIN ALTHERMA 3 H MT F+W 08KW (180L)	Reg. No.	011-1W0506
Certificate Holder			
Name	DAIKIN Europe N.V.		
Address	Zandvoordestraat 300	Zip	B-8400
City	Oostende	Country	Belgium
Certification Body	DIN CERTCO Gesellschaft für Konformitätsbewertung mbH		
Subtype title	DAIKIN ALTHERMA 3 H MT F+W 08KW (180L)		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R32		
Mass of Refrigerant	3.25 kg		
Certification Date	24.11.2021		
Testing basis	HP KEYMARK certification scheme rules rev. 9		

Model: EPRA08EV3 / ETBH12E(6V/9W)

Configure model	
Model name	EPRA08EV3 / ETBH12E(6V/9W)
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	6.17 kW	7.72 kW
El input	1.25 kW	2.63 kW
COP	4.92	2.94

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2

	+7°C/+12°C
El input	2.15 kW
Cooling capacity	6.81
EER	3.17

EN 14825

This information was generated by the HP KEYMARK database on 23 Jun 2022

	+7°C/+12°C
P _{designc}	6.5 kW
SEER	5.38
P _{dc Tj = 35°C}	6.81 kW
EER T _{j = 35°C}	3.17
P _{dc Tj = 30°C}	5.00 kW
EER T _{j = 30°C}	4.37
C _{dc}	0.98
P _{dc Tj = 25°C}	3.01 kW
EER T _{j = 25°C}	6.58
C _{dc}	0.94
P _{dc Tj = 20°C}	2.57 kW
EER T _{j = 20°C}	8.00
C _{dc}	0.91
P _{off}	25 W
PTO	3 W
PSB	25 W
PCK	0 W
Annual energy consumption Q _{ce}	725 kWh

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	44.0 dB(A)	44.0 dB(A)
Sound power level outdoor	53.0 dB(A)	53.0 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	184 %	134 %
Prated	8.30 kW	8.50 kW
SCOP	4.69	3.41
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.50 kW	7.60 kW
COP Tj = -7°C	3.10	2.21
Cdh Tj = -7 °C	1.0	1.0
Pdh Tj = +2°C	4.40 kW	4.60 kW
COP Tj = +2°C	4.76	3.37
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	4.30 kW	3.00 kW
COP Tj = +7°C	6.14	4.48
Cdh Tj = +7 °C	1.0	1.0

This information was generated by the HP KEYMARK database on 23 Jun 2022

Pdh Tj = 12°C	6.60 kW	3.70 kW
COP Tj = 12°C	7.84	5.98
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	7.50 kW	7.60 kW
COP Tj = Tbiv	3.10	2.21
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.90 kW	7.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.80	1.93
WTOL	35 °C	55 °C
Poff	21 W	21 W
PTO	24 W	24 W
PSB	21 W	21 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.40 kW	1.50 kW
Annual energy consumption Qhe	3659 kWh	5142 kWh

Model: EPRA08EV3 / ETBX12E(6V/9W)

Configure model	
Model name	EPRA08EV3 / ETBX12E(6V/9W)
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	6.17 kW	7.72 kW
El input	1.25 kW	2.63 kW
COP	4.92	2.94

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2

	+7°C/+12°C
El input	2.15 kW
Cooling capacity	6.81
EER	3.17

EN 14825

This information was generated by the HP KEYMARK database on 23 Jun 2022

	+7°C/+12°C
P _{designc}	6.50 kW
SEER	5.38
P _{dc Tj = 35°C}	6.81 kW
EER T _j = 35°C	3.17
P _{dc Tj = 30°C}	5.00 kW
EER T _j = 30°C	4.37
C _{dc}	0.980
P _{dc Tj = 25°C}	3.01 kW
EER T _j = 25°C	6.58
C _{dc}	0.940
P _{dc Tj = 20°C}	2.57 kW
EER T _j = 20°C	8.00
C _{dc}	0.910
P _{off}	25 W
PTO	3 W
PSB	25 W
PCK	0 W
Annual energy consumption Q _{ce}	725 kWh

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	44.0 dB(A)	44.0 dB(A)
Sound power level outdoor	53.0 dB(A)	53.0 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	188 %	136 %
Prated	8.30 kW	8.50 kW
SCOP	4.79	3.47
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.50 kW	7.60 kW
COP Tj = -7°C	3.10	2.21
Cdh Tj = -7 °C	1.0	1.0
Pdh Tj = +2°C	4.40 kW	4.60 kW
COP Tj = +2°C	4.76	3.37
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	4.30 kW	3.00 kW
COP Tj = +7°C	6.14	4.48
Cdh Tj = +7 °C	1.0	1.0

This information was generated by the HP KEYMARK database on 23 Jun 2022

Pdh Tj = 12°C	6.60 kW	3.70 kW
COP Tj = 12°C	7.84	5.98
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	7.50 kW	7.60 kW
COP Tj = Tbiv	3.10	2.21
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.90 kW	7.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.80	1.93
WTOL	35 °C	55 °C
Poff	21 W	21 W
PTO	24 W	24 W
PSB	21 W	21 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.40 kW	1.50 kW
Annual energy consumption Qhe	3582 kWh	5065 kWh

Model: EPRA08EV3 / ETVH12S18E(6V/9W)

Configure model	
Model name	EPRA08EV3 / ETVH12S18E(6V/9W)
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	6.17 kW	7.72 kW
El input	1.25 kW	2.63 kW
COP	4.92	2.94

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2**+7°C/+12°C**

El input

2.15 kW

Cooling capacity

6.81

EER

3.17

EN 14825

This information was generated by the HP KEYMARK database on 23 Jun 2022

	+7°C/+12°C
P _{designc}	6.5 kW
SEER	5.38
P _{dc Tj = 35°C}	6.81 kW
EER T _j = 35°C	3.17
P _{dc Tj = 30°C}	5.00 kW
EER T _j = 30°C	4.37
C _{dc}	0.98
P _{dc Tj = 25°C}	3.01 kW
EER T _j = 25°C	6.58
C _{dc}	0.94
P _{dc Tj = 20°C}	2.57 kW
EER T _j = 20°C	8.00
C _{dc}	0.91
P _{off}	25 W
PTO	3 W
PSB	25 W
PCK	0 W
Annual energy consumption Q _{ce}	725 kWh

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	44.0 dB(A)	44.0 dB(A)
Sound power level outdoor	53.0 dB(A)	53.0 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	184 %	134 %
Prated	8.3 kW	8.5 kW
SCOP	4.69	3.41
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.5 kW	7.6 kW
COP Tj = -7°C	3.10	2.21
Cdh Tj = -7 °C	1.0	1.0
Pdh Tj = +2°C	4.4 kW	4.6 kW
COP Tj = +2°C	4.76	3.37
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	4.3 kW	3.0 kW
COP Tj = +7°C	6.14	4.48
Cdh Tj = +7 °C	1.0	1.0

This information was generated by the HP KEYMARK database on 23 Jun 2022

Pdh Tj = 12°C	6.6 kW	3.7 kW
COP Tj = 12°C	7.84	5.98
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	7.5 kW	7.6 kW
COP Tj = Tbiv	3.10	2.21
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.9 kW	7.0 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.80	1.93
WTOL	35 °C	55 °C
Poff	21 W	21 W
PTO	24 W	24 W
PSB	21 W	21 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.4 kW	1.5 kW
Annual energy consumption Qhe	3659 kWh	5142 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	117 %
COP	2.72
Heating up time	1:57 h:min
Standby power input	51.7 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	240 l

Model: EPRA08EV3 / ETVH12SU18E6V

Configure model	
Model name	EPRA08EV3 / ETVH12SU18E6V
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	6.17 kW	7.72 kW
El input	1.25 kW	2.63 kW
COP	4.92	2.94

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2**+7°C/+12°C**

El input

2.15 kW

Cooling capacity

6.81

EER

3.17

EN 14825

This information was generated by the HP KEYMARK database on 23 Jun 2022

	+7°C/+12°C
P _{designc}	6.5 kW
SEER	5.38
P _{dc Tj = 35°C}	6.81 kW
EER T _j = 35°C	3.17
P _{dc Tj = 30°C}	5.00 kW
EER T _j = 30°C	4.37
C _{dc}	0.98
P _{dc Tj = 25°C}	3.01 kW
EER T _j = 25°C	6.58
C _{dc}	0.94
P _{dc Tj = 20°C}	2.57 kW
EER T _j = 20°C	8.00
C _{dc}	0.91
P _{off}	25 W
PTO	3 W
PSB	25 W
PCK	0 W
Annual energy consumption Q _{ce}	725 kWh

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	44.0 dB(A)	44.0 dB(A)
Sound power level outdoor	53.0 dB(A)	53.0 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	184 %	134 %
Prated	8.3 kW	8.5 kW
SCOP	4.69	3.41
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.5 kW	7.6 kW
COP Tj = -7°C	3.10	2.21
Cdh Tj = -7 °C	1.0	1.0
Pdh Tj = +2°C	4.4 kW	4.6 kW
COP Tj = +2°C	4.76	3.37
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	4.3 kW	3.0 kW
COP Tj = +7°C	6.14	4.48
Cdh Tj = +7 °C	1.0	1.0

This information was generated by the HP KEYMARK database on 23 Jun 2022

Pdh Tj = 12°C	6.6 kW	3.7 kW
COP Tj = 12°C	7.84	5.98
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	7.5 kW	7.6 kW
COP Tj = Tbiv	3.10	2.21
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.9 kW	7.0 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.80	1.93
WTOL	35 °C	55 °C
Poff	21 W	21 W
PTO	24 W	24 W
PSB	21 W	21 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.4 kW	1.5 kW
Annual energy consumption Qhe	3659 kWh	5142 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	117 %
COP	2.72
Heating up time	1:57 h:min
Standby power input	51.7 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	240 l

Model: EPRA08EV3 / ETVX12S18E(6V/9W)

Configure model	
Model name	EPRA08EV3 / ETVX12S18E(6V/9W)
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	6.17 kW	7.72 kW
El input	1.25 kW	2.63 kW
COP	4.92	2.94

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2**+7°C/+12°C**

El input

2.15 kW

Cooling capacity

6.81

EER

3.17

EN 14825

This information was generated by the HP KEYMARK database on 23 Jun 2022

	+7°C/+12°C
P _{designc}	6.5 kW
SEER	5.38
P _{dc Tj = 35°C}	6.81 kW
EER T _j = 35°C	3.17
P _{dc Tj = 30°C}	5.00 kW
EER T _j = 30°C	4.37
C _{dc}	0.98
P _{dc Tj = 25°C}	3.01 kW
EER T _j = 25°C	6.58
C _{dc}	0.94
P _{dc Tj = 20°C}	2.57 kW
EER T _j = 20°C	8.00
C _{dc}	0.91
P _{off}	25 W
PTO	3 W
PSB	25 W
PCK	0 W
Annual energy consumption Q _{ce}	725 kWh

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	44.0 dB(A)	44.0 dB(A)
Sound power level outdoor	53.0 dB(A)	53.0 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	188 %	136 %
Prated	8.3 kW	8.5 kW
SCOP	4.79	3.47
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.5 kW	7.6 kW
COP Tj = -7°C	3.10	2.21
Cdh Tj = -7 °C	1.0	1.0
Pdh Tj = +2°C	4.4 kW	4.6 kW
COP Tj = +2°C	4.76	3.37
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	4.3 kW	3.0 kW
COP Tj = +7°C	6.14	4.48
Cdh Tj = +7 °C	1.0	1.0

This information was generated by the HP KEYMARK database on 23 Jun 2022

Pdh Tj = 12°C	6.6 kW	3.7 kW
COP Tj = 12°C	7.84	5.98
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	7.5 kW	7.6 kW
COP Tj = Tbiv	3.10	2.21
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.9 kW	7.0 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.80	1.93
WTOL	35 °C	55 °C
Poff	21 W	21 W
PTO	24 W	24 W
PSB	21 W	21 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.4 kW	1.5 kW
Annual energy consumption Qhe	3582 kWh	5065 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	117 %
COP	2.72
Heating up time	1:57 h:min
Standby power input	51.7 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	240 l

Model: EPRA08EV3 / ETVZ12S18E(6V/9W)

Configure model	
Model name	EPRA08EV3 / ETVZ12S18E(6V/9W)
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	6.17 kW	7.72 kW
El input	1.25 kW	2.63 kW
COP	4.92	2.94

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2**+7°C/+12°C**

El input

2.15 kW

Cooling capacity

6.81

EER

3.17

EN 14825

This information was generated by the HP KEYMARK database on 23 Jun 2022

	+7°C/+12°C
P _{designc}	6.5 kW
SEER	5.38
P _{dc Tj = 35°C}	6.81 kW
EER T _j = 35°C	3.17
P _{dc Tj = 30°C}	5.00 kW
EER T _j = 30°C	4.37
C _{dc}	0.98
P _{dc Tj = 25°C}	3.01 kW
EER T _j = 25°C	6.58
C _{dc}	0.94
P _{dc Tj = 20°C}	2.57 kW
EER T _j = 20°C	8.00
C _{dc}	0.91
P _{off}	25 W
PTO	3 W
PSB	25 W
PCK	0 W
Annual energy consumption Q _{ce}	725 kWh

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	44.0 dB(A)	44.0 dB(A)
Sound power level outdoor	53.0 dB(A)	53.0 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	184 %	134 %
Prated	8.3 kW	8.5 kW
SCOP	4.69	3.41
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.5 kW	7.6 kW
COP Tj = -7°C	3.10	2.21
Cdh Tj = -7 °C	1.0	1.0
Pdh Tj = +2°C	4.4 kW	4.6 kW
COP Tj = +2°C	4.76	3.37
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	4.3 kW	3.0 kW
COP Tj = +7°C	6.14	4.48
Cdh Tj = +7 °C	1.0	1.0

This information was generated by the HP KEYMARK database on 23 Jun 2022

Pdh Tj = 12°C	6.6 kW	3.7 kW
COP Tj = 12°C	7.84	5.98
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	7.5 kW	7.6 kW
COP Tj = Tbiv	3.10	2.21
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.9 kW	7.0 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.80	1.93
WTOL	35 °C	55 °C
Poff	21 W	21 W
PTO	24 W	24 W
PSB	21 W	21 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.4 kW	1.5 kW
Annual energy consumption Qhe	3659 kWh	5142 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	117 %
COP	2.72
Heating up time	1:57 h:min
Standby power input	51.7 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	240 l

Model: EPRA08EW1 / ETBH12E(6V/9W)

Configure model	
Model name	EPRA08EW1 / ETBH12E(6V/9W)
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	6.17 kW	7.72 kW
El input	1.21 kW	2.53 kW
COP	5.10	3.05

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2**+7°C/+12°C**

El input

2.08 kW

Cooling capacity

6.81

EER

3.28

EN 14825

This information was generated by the HP KEYMARK database on 23 Jun 2022

	+7°C/+12°C
P _{designc}	6.5 kW
SEER	5.41
P _{dc Tj = 35°C}	6.81 kW
EER T _{j = 35°C}	3.28
P _{dc Tj = 30°C}	5.00 kW
EER T _{j = 30°C}	4.52
C _{dc}	0.97
P _{dc Tj = 25°C}	3.01 kW
EER T _{j = 25°C}	6.66
C _{dc}	0.94
P _{dc Tj = 20°C}	2.57 kW
EER T _{j = 20°C}	7.98
C _{dc}	0.91
P _{off}	31 W
PTO	0 W
PSB	31 W
PCK	0 W
Annual energy consumption Q _{ce}	719 kWh

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	44.0 dB(A)	44.0 dB(A)
Sound power level outdoor	53.0 dB(A)	53.0 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	190 %	138 %
Prated	8.3 kW	8.5 kW
SCOP	4.81	3.52
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.5 kW	7.6 kW
COP Tj = -7°C	3.20	2.30
Cdh Tj = -7 °C	1.0	1.0
Pdh Tj = +2°C	4.4 kW	4.6 kW
COP Tj = +2°C	4.93	3.50
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	4.3 kW	3.0 kW
COP Tj = +7°C	6.37	4.61
Cdh Tj = +7 °C	1.0	1.0

This information was generated by the HP KEYMARK database on 23 Jun 2022

Pdh Tj = 12°C	6.6 kW	3.7 kW
COP Tj = 12°C	8.13	6.16
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	7.5 kW	7.6 kW
COP Tj = Tbiv	3.20	2.30
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.9 kW	7.0 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.90	2.01
WTOL	35 °C	55 °C
Poff	27 W	27 W
PTO	24 W	24 W
PSB	27 W	27 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.4 kW	1.5 kW
Annual energy consumption Qhe	3561 kWh	4993 kWh

Model: EPRA08EW1 / ETBX12E(6V/9W)

Configure model	
Model name	EPRA08EW1 / ETBX12E(6V/9W)
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	6.17 kW	7.72 kW
El input	1.21 kW	2.53 kW
COP	5.10	3.05

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2

	+7°C/+12°C
El input	2.08 kW
Cooling capacity	6.81
EER	3.28

EN 14825

This information was generated by the HP KEYMARK database on 23 Jun 2022

	+7°C/+12°C
P _{designc}	6.5 kW
SEER	5.41
P _{dc Tj = 35°C}	6.81 kW
EER T _j = 35°C	3.28
P _{dc Tj = 30°C}	5.00 kW
EER T _j = 30°C	4.52
C _{dc}	0.97
P _{dc Tj = 25°C}	3.01 kW
EER T _j = 25°C	6.66
C _{dc}	0.94
P _{dc Tj = 20°C}	2.57 kW
EER T _j = 20°C	7.98
C _{dc}	0.91
P _{off}	31 W
PTO	0 W
PSB	31 W
PCK	0 W
Annual energy consumption Q _{ce}	719 kWh

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	44.0 dB(A)	44.0 dB(A)
Sound power level outdoor	53.0 dB(A)	53.0 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	195 %	141 %
Prated	8.3 kW	8.5 kW
SCOP	4.95	3.59
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.5 kW	7.6 kW
COP Tj = -7°C	3.20	2.30
Cdh Tj = -7 °C	1.0	1.0
Pdh Tj = +2°C	4.4 kW	4.6 kW
COP Tj = +2°C	4.93	3.50
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	4.3 kW	3.0 kW
COP Tj = +7°C	6.37	4.61
Cdh Tj = +7 °C	1.0	1.0

This information was generated by the HP KEYMARK database on 23 Jun 2022

Pdh Tj = 12°C	6.6 kW	3.7 kW
COP Tj = 12°C	8.13	6.16
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	7.5 kW	7.6 kW
COP Tj = Tbiv	3.20	2.30
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.9 kW	7.0 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.90	2.01
WTOL	35 °C	55 °C
Poff	27 W	27 W
PTO	24 W	24 W
PSB	27 W	27 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.4 kW	1.5 kW
Annual energy consumption Qhe	3462 kWh	4894 kWh

Model: EPRA08EW1 / ETVH12S18E(6V/9W)

Configure model	
Model name	EPRA08EW1 / ETVH12S18E(6V/9W)
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	6.17 kW	7.72 kW
El input	1.21 kW	2.53 kW
COP	5.10	3.05

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2	
	+7°C/+12°C
El input	2.08 kW
Cooling capacity	6.81
EER	3.28

EN 14825

This information was generated by the HP KEYMARK database on 23 Jun 2022

	+7°C/+12°C
P _{designc}	6.5 kW
SEER	5.41
P _{dc Tj = 35°C}	6.81 kW
EER T _{j = 35°C}	3.28
P _{dc Tj = 30°C}	5.00 kW
EER T _{j = 30°C}	4.52
C _{dc}	0.97
P _{dc Tj = 25°C}	3.01 kW
EER T _{j = 25°C}	6.66
C _{dc}	0.94
P _{dc Tj = 20°C}	2.57 kW
EER T _{j = 20°C}	7.98
C _{dc}	0.91
P _{off}	31 W
PTO	0 W
PSB	31 W
PCK	0 W
Annual energy consumption Q _{ce}	719 kWh

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	44.0 dB(A)	44.0 dB(A)
Sound power level outdoor	53.0 dB(A)	53.0 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	190 %	138 %
Prated	8.3 kW	8.5 kW
SCOP	4.81	3.52
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.5 kW	7.6 kW
COP Tj = -7°C	3.20	2.30
Cdh Tj = -7 °C	1.0	1.0
Pdh Tj = +2°C	4.4 kW	4.6 kW
COP Tj = +2°C	4.93	3.50
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	4.3 kW	3.0 kW
COP Tj = +7°C	6.37	4.61
Cdh Tj = +7 °C	1.0	1.0

This information was generated by the HP KEYMARK database on 23 Jun 2022

Pdh Tj = 12°C	6.6 kW	3.7 kW
COP Tj = 12°C	8.13	6.16
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	7.5 kW	7.6 kW
COP Tj = Tbiv	3.20	2.30
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.9 kW	7.0 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.90	2.01
WTOL	35 °C	55 °C
Poff	27 W	27 W
PTO	24 W	24 W
PSB	27 W	27 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.4 kW	1.5 kW
Annual energy consumption Qhe	3561 kWh	4993 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	120 %
COP	2.80
Heating up time	1:57 h:min
Standby power input	50.7 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	240 l

Model: EPRA08EW1 / ETVH12SU18E6V

Configure model	
Model name	EPRA08EW1 / ETVH12SU18E6V
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	6.17 kW	7.72 kW
El input	1.21 kW	2.53 kW
COP	5.10	3.05

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2

	+7°C/+12°C
El input	2.08 kW
Cooling capacity	6.81
EER	3.28

EN 14825

This information was generated by the HP KEYMARK database on 23 Jun 2022

	+7°C/+12°C
P _{designc}	6.5 kW
SEER	5.41
P _{dc Tj = 35°C}	6.81 kW
EER T _j = 35°C	3.28
P _{dc Tj = 30°C}	5.00 kW
EER T _j = 30°C	4.52
C _{dc}	0.97
P _{dc Tj = 25°C}	3.01 kW
EER T _j = 25°C	6.66
C _{dc}	0.94
P _{dc Tj = 20°C}	2.57 kW
EER T _j = 20°C	7.98
C _{dc}	0.91
P _{off}	31 W
PTO	0 W
PSB	31 W
PCK	0 W
Annual energy consumption Q _{ce}	719 kWh

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	44.0 dB(A)	44.0 dB(A)
Sound power level outdoor	53.0 dB(A)	53.0 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	190 %	138 %
Prated	8.3 kW	8.5 kW
SCOP	4.81	3.52
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.5 kW	7.6 kW
COP Tj = -7°C	3.20	2.30
Cdh Tj = -7 °C	1.0	1.0
Pdh Tj = +2°C	4.4 kW	4.6 kW
COP Tj = +2°C	4.93	3.50
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	4.3 kW	3.0 kW
COP Tj = +7°C	6.37	4.61
Cdh Tj = +7 °C	1.0	1.0

This information was generated by the HP KEYMARK database on 23 Jun 2022

Pdh Tj = 12°C	6.6 kW	3.7 kW
COP Tj = 12°C	8.13	6.16
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	7.5 kW	7.6 kW
COP Tj = Tbiv	3.20	2.30
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.9 kW	7.0 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.90	2.01
WTOL	35 °C	55 °C
Poff	27 W	27 W
PTO	24 W	24 W
PSB	27 W	27 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.4 kW	1.5 kW
Annual energy consumption Qhe	3561 kWh	4993 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	120 %
COP	2.80
Heating up time	1:57 h:min
Standby power input	50.7 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	240 l

Model: EPRA08EW1 / ETVX12S18E(6V/9W)

Configure model	
Model name	EPRA08EW1 / ETVX12S18E(6V/9W)
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	6.17 kW	7.72 kW
El input	1.21 kW	2.53 kW
COP	5.10	3.05

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2**+7°C/+12°C**

El input

2.08 kW

Cooling capacity

6.81

EER

3.28

EN 14825

This information was generated by the HP KEYMARK database on 23 Jun 2022

	+7°C/+12°C
P _{designc}	6.50 kW
SEER	5.41
P _{dc Tj = 35°C}	6.81 kW
EER T _{j = 35°C}	3.28
P _{dc Tj = 30°C}	5.00 kW
EER T _{j = 30°C}	4.52
C _{dc}	0.970
P _{dc Tj = 25°C}	3.01 kW
EER T _{j = 25°C}	6.66
C _{dc}	0.940
P _{dc Tj = 20°C}	2.57 kW
EER T _{j = 20°C}	7.98
C _{dc}	0.910
P _{off}	31 W
PTO	0 W
PSB	31 W
PCK	0 W
Annual energy consumption Q _{ce}	719 kWh

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	44.0 dB(A)	44.0 dB(A)
Sound power level outdoor	53.0 dB(A)	53.0 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	195 %	141 %
Prated	8.3 kW	8.5 kW
SCOP	4.95	3.59
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.5 kW	7.6 kW
COP Tj = -7°C	3.20	2.30
Cdh Tj = -7 °C	1.0	1.0
Pdh Tj = +2°C	4.4 kW	4.6 kW
COP Tj = +2°C	4.93	3.50
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	4.3 kW	3.0 kW
COP Tj = +7°C	6.37	4.61
Cdh Tj = +7 °C	1.0	1.0

This information was generated by the HP KEYMARK database on 23 Jun 2022

Pdh Tj = 12°C	6.6 kW	3.7 kW
COP Tj = 12°C	8.13	6.16
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	7.5 kW	7.6 kW
COP Tj = Tbiv	3.20	2.30
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.9 kW	7.0 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.90	2.01
WTOL	35 °C	55 °C
Poff	27 W	27 W
PTO	24 W	24 W
PSB	27 W	27 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.4 kW	1.5 kW
Annual energy consumption Qhe	3462 kWh	4894 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	120 %
COP	2.80
Heating up time	1:57 h:min
Standby power input	50.7 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	240 l

Model: EPRA08EW1 / ETVZ12S18E(6V/9W)

Configure model	
Model name	EPRA08EW1 / ETVZ12S18E(6V/9W)
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	No
Cooling mode application (optional)	n/a

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	6.17 kW	7.72 kW
El input	1.21 kW	2.53 kW
COP	5.10	3.05

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2	
	+7°C/+12°C
El input	2.08 kW
Cooling capacity	6.81
EER	3.28

EN 14825

This information was generated by the HP KEYMARK database on 23 Jun 2022

	+7°C/+12°C
P _{designc}	6.5 kW
SEER	5.41
P _{dc Tj = 35°C}	6.81 kW
EER T _{j = 35°C}	3.28
P _{dc Tj = 30°C}	5.00 kW
EER T _{j = 30°C}	4.52
C _{dc}	0.97
P _{dc Tj = 25°C}	3.01 kW
EER T _{j = 25°C}	6.66
C _{dc}	0.94
P _{dc Tj = 20°C}	2.57 kW
EER T _{j = 20°C}	7.98
C _{dc}	0.91
P _{off}	31 W
PTO	0 W
PSB	31 W
PCK	0 W
Annual energy consumption Q _{ce}	719 kWh

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	44.0 dB(A)	44.0 dB(A)
Sound power level outdoor	53.0 dB(A)	53.0 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	190 %	138 %
Prated	8.3 kW	8.5 kW
SCOP	4.81	3.52
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.5 kW	7.6 kW
COP Tj = -7°C	3.20	2.30
Cdh Tj = -7 °C	1.0	1.0
Pdh Tj = +2°C	4.4 kW	4.6 kW
COP Tj = +2°C	4.93	3.50
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	4.3 kW	3.0 kW
COP Tj = +7°C	6.37	4.61
Cdh Tj = +7 °C	1.0	1.0

This information was generated by the HP KEYMARK database on 23 Jun 2022

Pdh Tj = 12°C	6.6 kW	3.7 kW
COP Tj = 12°C	8.13	6.16
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	7.5 kW	7.6 kW
COP Tj = Tbiv	3.20	2.30
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.9 kW	7.0 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.90	2.01
WTOL	35 °C	55 °C
Poff	27 W	27 W
PTO	24 W	24 W
PSB	27 W	27 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.4 kW	1.5 kW
Annual energy consumption Qhe	3561 kWh	4993 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	120 %
COP	2.80
Heating up time	1:57 h:min
Standby power input	50.7 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	240 l

Model: EPRA08EV3 / ETBH12E(6V/9W) + cooling kit

Configure model	
Model name	EPRA08EV3 / ETBH12E(6V/9W) + cooling kit
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	6.17 kW	7.72 kW
El input	1.25 kW	2.63 kW
COP	4.92	2.94

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2**+7°C/+12°C**

El input

2.15 kW

Cooling capacity

6.81

EER

3.17

EN 14825

This information was generated by the HP KEYMARK database on 23 Jun 2022

	+7°C/+12°C
P _{designc}	6.50 kW
SEER	5.38
P _{dc Tj = 35°C}	6.81 kW
EER T _{j = 35°C}	3.17
P _{dc Tj = 30°C}	5.00 kW
EER T _{j = 30°C}	4.37
C _{dc}	0.980
P _{dc Tj = 25°C}	3.01 kW
EER T _{j = 25°C}	6.58
C _{dc}	0.940
P _{dc Tj = 20°C}	2.57 kW
EER T _{j = 20°C}	8.00
C _{dc}	0.910
P _{off}	25 W
PTO	3 W
PSB	25 W
PCK	0 W
Annual energy consumption Q _{ce}	725 kWh

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	44.0 dB(A)	44.0 dB(A)
Sound power level outdoor	53.0 dB(A)	53.0 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	188 %	136 %
Prated	8.30 kW	8.50 kW
SCOP	4.79	3.47
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.50 kW	7.60 kW
COP Tj = -7°C	3.10	2.21
Cdh Tj = -7 °C	1.0	1.0
Pdh Tj = +2°C	4.40 kW	4.60 kW
COP Tj = +2°C	4.76	3.37
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	4.30 kW	3.00 kW
COP Tj = +7°C	6.14	4.48
Cdh Tj = +7 °C	1.0	1.0

This information was generated by the HP KEYMARK database on 23 Jun 2022

Pdh Tj = 12°C	6.60 kW	3.70 kW
COP Tj = 12°C	7.84	5.98
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	7.50 kW	7.60 kW
COP Tj = Tbiv	3.10	2.21
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.90 kW	7.00 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.80	1.93
WTOL	35 °C	55 °C
Poff	21 W	21 W
PTO	24 W	24 W
PSB	21 W	21 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.40 kW	1.50 kW
Annual energy consumption Qhe	3582 kWh	5065 kWh

Model: EPRA08EV3 / ETVH12S18E(6V/9W) + cooling kit

Configure model	
Model name	EPRA08EV3 / ETVH12S18E(6V/9W) + cooling kit
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	6.17 kW	7.72 kW
El input	1.25 kW	2.63 kW
COP	4.92	2.94

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2

	+7°C/+12°C
El input	2.15 kW
Cooling capacity	6.81
EER	3.17

EN 14825

This information was generated by the HP KEYMARK database on 23 Jun 2022

	+7°C/+12°C
P _{designc}	6.5 kW
SEER	5.38
P _{dc Tj = 35°C}	6.81 kW
EER T _{j = 35°C}	3.17
P _{dc Tj = 30°C}	5.00 kW
EER T _{j = 30°C}	4.37
C _{dc}	0.98
P _{dc Tj = 25°C}	3.01 kW
EER T _{j = 25°C}	6.58
C _{dc}	0.94
P _{dc Tj = 20°C}	2.57 kW
EER T _{j = 20°C}	8.00
C _{dc}	0.91
P _{off}	25 W
PTO	3 W
PSB	25 W
PCK	0 W
Annual energy consumption Q _{ce}	725 kWh

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	44.0 dB(A)	44.0 dB(A)
Sound power level outdoor	53.0 dB(A)	53.0 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	188 %	136 %
Prated	8.3 kW	8.5 kW
SCOP	4.79	3.47
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.5 kW	7.6 kW
COP Tj = -7°C	3.10	2.21
Cdh Tj = -7 °C	1.0	1.0
Pdh Tj = +2°C	4.4 kW	4.6 kW
COP Tj = +2°C	4.76	3.37
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	4.3 kW	3.0 kW
COP Tj = +7°C	6.14	4.48
Cdh Tj = +7 °C	1.0	1.0

This information was generated by the HP KEYMARK database on 23 Jun 2022

Pdh Tj = 12°C	6.6 kW	3.7 kW
COP Tj = 12°C	7.84	5.98
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	7.5 kW	7.6 kW
COP Tj = Tbiv	3.10	2.21
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.9 kW	7.0 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.80	1.93
WTOL	35 °C	55 °C
Poff	21 W	21 W
PTO	24 W	24 W
PSB	21 W	21 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.4 kW	1.5 kW
Annual energy consumption Qhe	3582 kWh	5065 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	117 %
COP	2.72
Heating up time	1:57 h:min
Standby power input	51.7 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	240 l

Model: EPRA08EW1 / ETBH12E(6V/9W) + cooling kit

Configure model	
Model name	EPRA08EW1 / ETBH12E(6V/9W) + cooling kit
Application	Heating (medium temp)
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	6.17 kW	7.72 kW
El input	1.21 kW	2.53 kW
COP	5.10	3.05

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2

	+7°C/+12°C
El input	2.08 kW
Cooling capacity	6.81
EER	3.28

EN 14825

This information was generated by the HP KEYMARK database on 23 Jun 2022

	+7°C/+12°C
P _{designc}	6.5 kW
SEER	5.41
P _{dc Tj = 35°C}	6.81 kW
EER T _{j = 35°C}	3.28
P _{dc Tj = 30°C}	5.00 kW
EER T _{j = 30°C}	4.52
C _{dc}	0.97
P _{dc Tj = 25°C}	3.01 kW
EER T _{j = 25°C}	6.66
C _{dc}	0.94
P _{dc Tj = 20°C}	2.57 kW
EER T _{j = 20°C}	7.98
C _{dc}	0.91
P _{off}	31 W
PTO	0 W
PSB	31 W
PCK	0 W
Annual energy consumption Q _{ce}	719 kWh

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	44.0 dB(A)	44.0 dB(A)
Sound power level outdoor	53.0 dB(A)	53.0 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	195 %	141 %
Prated	8.3 kW	8.5 kW
SCOP	4.95	3.59
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.5 kW	7.6 kW
COP Tj = -7°C	3.20	2.30
Cdh Tj = -7 °C	1.0	1.0
Pdh Tj = +2°C	4.4 kW	4.6 kW
COP Tj = +2°C	4.93	3.50
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	4.3 kW	3.0 kW
COP Tj = +7°C	6.37	4.61
Cdh Tj = +7 °C	1.0	1.0

This information was generated by the HP KEYMARK database on 23 Jun 2022

Pdh Tj = 12°C	6.6 kW	3.7 kW
COP Tj = 12°C	8.13	6.16
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	7.5 kW	7.6 kW
COP Tj = Tbiv	3.20	2.30
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.9 kW	7.0 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.90	2.01
WTOL	35 °C	55 °C
Poff	27 W	27 W
PTO	24 W	24 W
PSB	27 W	27 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.4 kW	1.5 kW
Annual energy consumption Qhe	3462 kWh	4894 kWh

Model: EPRA08EW1 / ETVH12S18E(6V/9W) + cooling kit

Configure model	
Model name	EPRA08EW1 / ETVH12S18E(6V/9W) + cooling kit
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	6.17 kW	7.72 kW
El input	1.21 kW	2.53 kW
COP	5.10	3.05

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2**+7°C/+12°C**

El input

2.08 kW

Cooling capacity

6.81

EER

3.28

EN 14825

This information was generated by the HP KEYMARK database on 23 Jun 2022

	+7°C/+12°C
P _{designc}	6.50 kW
SEER	5.41
P _{dc Tj = 35°C}	6.81 kW
EER T _{j = 35°C}	3.28
P _{dc Tj = 30°C}	5.00 kW
EER T _{j = 30°C}	4.52
C _{dc}	0.970
P _{dc Tj = 25°C}	3.01 kW
EER T _{j = 25°C}	6.66
C _{dc}	0.940
P _{dc Tj = 20°C}	2.57 kW
EER T _{j = 20°C}	7.98
C _{dc}	0.910
P _{off}	31 W
PTO	0 W
PSB	31 W
PCK	0 W
Annual energy consumption Q _{ce}	719 kWh

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	44.0 dB(A)	44.0 dB(A)
Sound power level outdoor	53.0 dB(A)	53.0 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	195 %	141 %
Prated	8.3 kW	8.5 kW
SCOP	4.95	3.59
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.5 kW	7.6 kW
COP Tj = -7°C	3.20	2.30
Cdh Tj = -7 °C	1.0	1.0
Pdh Tj = +2°C	4.4 kW	4.6 kW
COP Tj = +2°C	4.93	3.50
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	4.3 kW	3.0 kW
COP Tj = +7°C	6.37	4.61
Cdh Tj = +7 °C	1.0	1.0

This information was generated by the HP KEYMARK database on 23 Jun 2022

Pdh Tj = 12°C	6.6 kW	3.7 kW
COP Tj = 12°C	8.13	6.16
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	7.5 kW	7.6 kW
COP Tj = Tbiv	3.20	2.30
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.9 kW	7.0 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.90	2.01
WTOL	35 °C	55 °C
Poff	27 W	27 W
PTO	24 W	24 W
PSB	27 W	27 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.4 kW	1.5 kW
Annual energy consumption Qhe	3462 kWh	4894 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	120 %
COP	2.80
Heating up time	1:57 h:min
Standby power input	50.7 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	240 l

Model: EPRA08EV3 / ETVZ12S18E(6V/9W) + cooling kit

Configure model	
Model name	EPRA08EV3 / ETVZ12S18E(6V/9W) + cooling kit
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	1x230V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	6.17 kW	7.72 kW
El input	1.25 kW	2.63 kW
COP	4.92	2.94

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2**+7°C/+12°C**

El input

2.15 kW

Cooling capacity

6.81

EER

3.17

EN 14825

This information was generated by the HP KEYMARK database on 23 Jun 2022

	+7°C/+12°C
P _{designc}	6.5 kW
SEER	5.38
P _{dc Tj = 35°C}	6.81 kW
EER T _j = 35°C	3.17
P _{dc Tj = 30°C}	5.00 kW
EER T _j = 30°C	4.37
C _{dc}	0.98
P _{dc Tj = 25°C}	3.01 kW
EER T _j = 25°C	6.58
C _{dc}	0.94
P _{dc Tj = 20°C}	2.57 kW
EER T _j = 20°C	8.00
C _{dc}	0.91
P _{off}	25 W
PTO	3 W
PSB	25 W
PCK	0 W
Annual energy consumption Q _{ce}	725 kWh

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	44.0 dB(A)	44.0 dB(A)
Sound power level outdoor	53.0 dB(A)	53.0 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	188 %	136 %
Prated	8.3 kW	8.5 kW
SCOP	4.79	3.47
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.5 kW	7.6 kW
COP Tj = -7°C	3.10	2.21
Cdh Tj = -7 °C	1.0	1.0
Pdh Tj = +2°C	4.4 kW	4.6 kW
COP Tj = +2°C	4.76	3.37
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	4.3 kW	3.0 kW
COP Tj = +7°C	6.14	4.48
Cdh Tj = +7 °C	1.0	1.0

This information was generated by the HP KEYMARK database on 23 Jun 2022

Pdh Tj = 12°C	6.6 kW	3.7 kW
COP Tj = 12°C	7.84	5.98
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	7.5 kW	7.6 kW
COP Tj = Tbiv	3.10	2.21
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.9 kW	7.0 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.80	1.93
WTOL	35 °C	55 °C
Poff	21 W	21 W
PTO	24 W	24 W
PSB	21 W	21 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.4 kW	1.5 kW
Annual energy consumption Qhe	3582 kWh	5065 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	117 %
COP	2.72
Heating up time	1:57 h:min
Standby power input	51.7 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	240 l

Model: EPRA08EW1 / ETVZ12S18E(6V/9W) + cooling kit

Configure model	
Model name	EPRA08EW1 / ETVZ12S18E(6V/9W) + cooling kit
Application	Heating + DHW + low temp
Units	Indoor + Outdoor
Climate Zone	n/a
Reversibility	Yes
Cooling mode application (optional)	+7°C/12°C

General Data	
Power supply	3x400V 50Hz

Heating

EN 14511-2		
	Low temperature	Medium temperature
Heat output	6.17 kW	7.72 kW
El input	1.21 kW	2.53 kW
COP	5.10	3.05

EN 14511-4	
Shutting off the heat transfer medium flow	passed
Complete power supply failure	passed
Defrost test	passed
Starting and operating test	passed

Cooling

EN 14511-2

	+7°C/+12°C
El input	2.08 kW
Cooling capacity	6.81
EER	3.28

EN 14825

This information was generated by the HP KEYMARK database on 23 Jun 2022

	+7°C/+12°C
P _{designc}	6.50 kW
SEER	5.41
P _{dc Tj = 35°C}	6.81 kW
EER T _j = 35°C	3.28
P _{dc Tj = 30°C}	5.00 kW
EER T _j = 30°C	4.52
C _{dc}	0.970
P _{dc Tj = 25°C}	3.01 kW
EER T _j = 25°C	6.66
C _{dc}	0.940
P _{dc Tj = 20°C}	2.57 kW
EER T _j = 20°C	7.98
C _{dc}	0.910
P _{off}	31 W
PTO	0 W
PSB	31 W
PCK	0 W
Annual energy consumption Q _{ce}	719 kWh

Average Climate

EN 12102-1		
	Low temperature	Medium temperature
Sound power level indoor	44.0 dB(A)	44.0 dB(A)
Sound power level outdoor	53.0 dB(A)	53.0 dB(A)

EN 14825		
	Low temperature	Medium temperature
η_s	195 %	141 %
Prated	8.3 kW	8.5 kW
SCOP	4.95	3.59
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	7.5 kW	7.6 kW
COP Tj = -7°C	3.20	2.30
Cdh Tj = -7 °C	1.0	1.0
Pdh Tj = +2°C	4.4 kW	4.6 kW
COP Tj = +2°C	4.93	3.50
Cdh Tj = +2 °C	1.0	1.0
Pdh Tj = +7°C	4.3 kW	3.0 kW
COP Tj = +7°C	6.37	4.61
Cdh Tj = +7 °C	1.0	1.0

This information was generated by the HP KEYMARK database on 23 Jun 2022

Pdh Tj = 12°C	6.6 kW	3.7 kW
COP Tj = 12°C	8.13	6.16
Cdh Tj = +12 °C	1.0	1.0
Pdh Tj = Tbiv	7.5 kW	7.6 kW
COP Tj = Tbiv	3.20	2.30
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.9 kW	7.0 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.90	2.01
WTOL	35 °C	55 °C
Poff	27 W	27 W
PTO	24 W	24 W
PSB	27 W	27 W
PCK	0 W	0 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	1.4 kW	1.5 kW
Annual energy consumption Qhe	3462 kWh	4894 kWh

Domestic Hot Water (DHW)

Average Climate

EN 16147	
Declared load profile	L
Efficiency η_{DHW}	120 %
COP	2.80
Heating up time	1:57 h:min
Standby power input	50.7 W
Reference hot water temperature	52.5 °C
Mixed water at 40°C	240 l